

No. 73 /dt 12.3.2025
To

The Principal,
Gyana Vikash English Medium School,
Govindapur, Ganjam (Odisha).

Sub : Water Quality Test Report of Gyana Vikash English Medium School.

Sir,

With reference to the water samples submitted by you at District Water Testing Laboratory, Berhampur, the same has been tested for the following Parameters.

Sl.No.	Parameter	Units	Permissible Limit	Testing Value
				Bore water
1	Alkalinity	Mg/ltr	600	164.0
2	Chloride	Mg/ltr	1000	152.0
3	Fluoride	Mg/ltr	1.5	0.474
4	Total Hardness	Mg/ltr	600	196.0
5	Iron	Mg/ltr	1.0	0.128
6	pH	--	6.5-8.5	7.16
7	Elec.Conductivity	(μ mho/cm)	--	342.5
8	TDS	Mg/ltr	2000	205.5
9	Turbidity	NTU	5	1.38

Water is safe for Drinking as the testing values are under permissible limit.

Yours faithfully,

[Signature]
12.3.2025
CEO-cum-Executive Engineer(RWSS)
Chief Executive Officer

-cum-
Executive Engineer
District Water Testing Laboratory
RWSS Division, Berhampur

[Signature]
Principal
Gyana Vikash English Medium School
Berhampur (Gm.)